

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-1374:104 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: NCA, 1735 Mattawa Ave., Mississauga, Ontario, Canada L4X 1K5
Contact: Darryl Miller (905) 270-0480 Fax (905) 270-8741

DESIGN: Model SSD-RD leakage damper. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, leakage rating and UL label.

APPROVAL: Listed as a Class 1-A leakage-rated damper for use with the following operator/actuators: Johnson Controls Model D-3153-7, Johnson Controls Model 03073-2, Johnson Controls Model D-3073-7, Honeywell Model MP909F1016, Multiproducts Model 2920 or Barber Coleman Model MA418.

NOTE: Formerly 3230-1044:105



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager